

95 年 8 月南部科學工業園區高雄園區污水處理廠放流水質

日期	Temp (°C)	pH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
8/4	28.9	7.3	7.2	55.2	--
8/7	30.6	7.2	5.3	35.3	--
8/8	29.9	7.1	0.4	49.4	--
8/9	28.5	7.3	2.0	42.4	--
8/10	28.0	7.2	4.8	80.0	--
8/11	28.8	7.0	3.7	64.0	--
8/12	31.1	7.3	4.8	38.7	--
8/15	28.8	7.2	7.7	31.0	--
8/16	30.3	7.2	4.6	39.3	--
8/17	29.1	7.3	11.2	55.1	--
8/18	27.5	7.8	3.0	45.7	--
8/19	28.4	7.2	6.6	46.4	--
8/22	28.4	7.3	3.6	46.4	--
8/23	28.1	7.4	4.4	29.1	11.8
8/24	27.9	7.6	2.5	15.5	7.2
8/25	26.7	7.8	2.0	30.0	6.6
8/28	26.7	7.7	1.2	20.3	--
8/29	28.3	7.3	2.3	16.0	5.6
8/30	27.9	7.3	1.0	16.8	2.6
8/31	27.8	7.8	1.8	12.0	3.5
平均	28.6	7.4	4.0	38.4	6.2