

## 95 年 9 月南部科學工業園區高雄園區污水處理廠放流水質

日期	Temp (°C)	pH	SS (mg/L)	COD (mg/L)	BOD <sub>5</sub> (mg/L)
9/1	27.3	7.7	4.2	12.1	--
9/4	27.1	7.8	1.2	11.9	--
9/5	27.7	7.7	1.4	15.9	1.9
9/6	27.3	7.5	1.4	11.9	2.6
9/7	27.6	7.5	0.8	15.6	2.8
9/8	28.2	7.7	0.9	16.1	--
9/11	27.8	7.3	0.5	25.8	--
9/12	27.9	7.2	1.2	18.7	3.4
9/13	27.2	7.4	1.0	16.7	4.0
9/14	26.8	7.4	0.8	29.4	6.9
9/15	28.3	7.0	1.6	19.6	--
9/16	27.6	6.4	4.6	17.2	--
9/17	28.0	6.4	2.3	7.8	--
9/18	27.2	6.9	0.9	10.6	--
9/19	27.2	7.2	0.9	23.1	--
9/20	27.3	7.1	0.6	8.4	2.7
9/21	27.0	7.0	0.8	14.8	4.1
9/22	26.4	7.2	0.8	21.4	4.2
9/23	27.2	7.3	1.0	10.4	--
9/24	27.3	7.4	0.7	15.2	--
9/25	27.4	7.1	0.5	28.7	9.6
9/26	27.3	7.2	0.8	28.0	7.3
9/27	27.5	7.1	0.5	9.3	3.9
9/28	27.5	7.2	0.4	17.1	2.9
9/29	27.1	7.1	0.6	20.5	--
9/30	27.9	6.9	1.4	19.3	--
平均	27.4	7.2	1.2	17.1	4.3