

95 年 11 月南部科學工業園區高雄園區污水處理流水質

日期	Temp (°C)	pH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
11/1	25.0	6.7	1.6	27.2	6.5
11/2	25.5	6.7	1.8	25.8	7.4
11/3	24.6	6.7	1.7	26.1	--
11/4	25.4	6.9	1.6	17.9	--
11/5	25.4	7.0	1.8	27.7	--
11/6	25.8	7.6	0.9	16.3	--
11/7	25.9	7.1	0.5	18.3	2.6
11/8	25.3	7.1	1.0	16.8	3.3
11/9	25.9	7.4	1.1	12.7	3.5
11/10	26.5	7.2	0.8	16.0	--
11/11	25.7	7.0	1.2	10.5	--
11/12	25.1	7.1	0.9	15.3	--
11/13	24.8	7.0	0.8	9.7	--
11/14	25.7	7.2	1.0	19.0	2.9
11/15	23.7	7.2	1.8	4.8	3.5
11/16	25.3	7.2	1.0	16.6	5.6
11/17	24.1	7.0	0.6	17.8	--
11/18	25.7	6.9	1.0	8.9	--
11/19	25.9	7.0	0.6	22.6	--
11/20	26.4	6.8	1.0	18.6	--
11/21	25.8	7.1	0.9	31.6	4.8
11/22	25.4	7.0	0.9	18.6	5.1
11/23	24.1	7.0	0.8	28.6	5.1
11/24	25.6	7.1	1.4	19.4	--
11/25	25.1	7.1	1.1	8.9	--
11/26	25.8	7.0	0.6	16.1	--
11/27	24.1	7.0	0.6	16.9	--
11/28	24.7	6.9	1.0	29.2	9.8
11/29	24.6	7.0	1.0	23.7	7.1
11/30	24.4	7.1	0.6	16.0	4.9
平均	25.2	7.0	1.1	18.6	5.2