

95 年 12 月南部科學工業園區高雄園區污水處理廠放流水質

日期	Temp (°C)	pH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
12/1	23.4	7.1	0.7	19.6	--
12/2	24.5	7.0	1.2	11.9	--
12/3	24.1	7.0	0.8	21.4	--
12/4	23.4	7.0	0.8	21.4	--
12/5	24.9	7.0	0.9	18.3	4.2
12/6	24.8	6.9	1.1	19.0	4.8
12/7	24.7	6.9	1.2	25.4	2.6
12/8	25.4	6.8	0.7	7.1	--
12/9	22.5	7.1	1.6	13.4	--
12/10	22.4	7.2	0.8	11.0	--
12/11	20.5	7.0	1.3	13.4	--
12/12	22.7	7.0	1.2	10.2	4.5
12/13	23.1	7.0	1.5	21.7	3.3
12/14	23.9	7.1	1.3	23.0	2.7
12/15	23.4	7.0	1.0	23.9	--
12/16	21.3	7.2	1.4	16.6	--
12/17	22.1	6.9	1.9	17.4	--
12/18	22.3	7.2	1.1	19.7	--
12/19	21.6	7.2	0.5	21.0	4.3
12/20	22.4	7.0	1.7	27.0	5.0
12/21	22.8	7.1	1.4	18.2	4.5
12/22	22.8	7.1	1.0	20.2	--
12/23	21.5	7.3	0.4	15.4	--
12/24	22.0	7.3	1.0	14.5	--
12/25	21.2	7.1	1.0	21.8	--
12/26	21.4	7.1	0.8	17.5	--
12/27	21.5	7.0	0.4	10.3	2.6
12/28	22.1	7.2	1.3	9.7	2.3
12/29	20.0	7.1	1.6	13.5	1.9
12/30	20.9	6.8	0.8	13.4	--
12/31	20.8	7.0	0.6	19.7	--
平均	22.6	7.1	1.1	17.3	3.6