

96 年 1 月南部科學工業園區高雄園區污水處理廠放流水質

日期	Temp (°C)	pH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
1/1	21.7	7.0	0.7	15.0	--
1/2	20.4	6.8	1.2	14.2	2.0
1/3	21.5	7.2	6.9	27.5	2.1
1/4	22.1	7.0	0.8	10.9	2.0
1/5	23.4	7.3	0.9	15.8	--
1/6	18.6	7.1	0.8	6.4	--
1/7	19.1	7.1	0.6	8.8	--
1/8	19.3	7.0	1.0	9.6	--
1/9	19.8	7.2	1.4	17.8	7.8
1/10	20.5	7.2	1.0	15.2	1.6
1/11	21.2	7.1	0.8	15.2	1.4
1/12	20.6	7.0	0.6	16.6	--
1/13	24.1	7.3	0.7	20.2	--
1/14	23.6	7.3	0.8	17.9	--
1/15	23.5	7.0	0.4	14.0	--
1/16	23.0	7.1	1.0	20.2	1.4
1/17	22.9	7.0	1.5	9.4	1.5
1/18	22.2	7.1	1.4	11.0	1.4
1/19	22.0	7.0	1.0	8.8	--
1/20	18.2	7.3	0.8	13.4	--
1/21	18.2	7.2	0.8	15.0	--
1/22	21.2	7.1	1.1	18.9	--
1/23	20.3	7.2	1.5	18.8	1.4
1/24	21.9	7.1	1.0	18.2	1.8
1/25	21.2	7.1	1.0	20.6	1.4
1/26	20.2	6.9	1.0	15.7	--
1/27	18.5	7.2	1.2	14.2	--
1/28	18.3	7.1	1.0	8.7	--
1/29	17.6	6.6	0.8	15.8	--
1/30	19.0	7.0	0.6	21.3	1.5
1/31	20.1	7.2	1.3	19.3	1.4
平均	20.8	7.1	1.1	15.3	2.1