

96年2月南部科學工業園區高雄園區污水處理廠放流水質

日期	Temp (°C)	pH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
2/1	19.2	7.1	1.3	13.4	2.2
2/2	18.1	7.0	1.5	16.9	--
2/3	21.7	7.2	1.5	16.8	--
2/4	21.3	7.3	1.2	20.8	--
2/5	19.1	7.1	1.4	24.8	--
2/6	21.0	7.1	2.6	26.6	1.3
2/7	20.3	7.0	2.6	48.2	5.7
2/8	21.6	7.6	2.7	48.5	4.7
2/9	21.7	6.9	1.7	60.4	--
2/10	20.8	7.1	1.4	22.9	--
2/11	22.3	7.1	1.2	15.0	--
2/12	21.3	7.2	0.8	37.9	--
2/13	22.1	6.8	0.4	7.2	1.5
2/14	21.4	7.1	0.7	17.3	2.0
2/15	22.3	6.8	0.5	13.5	1.7
2/16	21.8	7.2	2.0	23.8	--
2/17	24.0	7.4	1.0	21.4	--
2/18	23.5	7.2	1.0	15.9	--
2/19	24.3	7.4	1.2	14.3	--
2/20	23.3	7.4	0.2	11.1	--
2/21	22.6	7.4	0.6	19.1	--
2/22	21.2	7.6	0.6	15.1	--
2/23	23.1	7.7	1.0	31.8	--
2/24	22.5	7.6	0.8	15.9	--
2/25	23.2	7.5	0.6	19.1	--
2/26	23.1	7.1	0.8	18.3	--
2/27	22.1	7.0	1.0	19.5	--
2/28	23.1	6.9	0.6	15.7	--
平均	21.9	7.2	1.2	22.5	2.7