

96 年 3 月南部科學工業園區高雄園區污水處理廠放流水質

日期	Temp (°C)	pH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
3/1	23.0	7.0	0.8	23.5	1.8
3/2	22.9	6.9	0.7	10.9	1.9
3/3	22.4	7.0	0.7	23.4	--
3/4	23.8	7.1	1.0	18.3	--
3/5	23.6	7.2	1.6	22.2	--
3/6	19.9	7.1	1.7	23.6	2.4
3/7	22.1	7.4	1.2	17.5	1.4
3/8	21.9	7.2	1.4	13.6	1.5
3/9	22.4	7.0	1.5	8.7	--
3/10	23.4	7.5	1.2	11.8	--
3/11	22.8	7.5	0.8	13.8	--
3/12	21.6	7.3	1.5	9.5	--
3/13	21.9	7.1	1.1	10.2	1.4
3/14	23.4	7.5	3.1	19.0	1.6
3/15	23.8	7.3	3.1	17.5	2.5
3/16	23.7	7.4	4.1	19.0	--
3/17	21.3	7.7	2.6	14.9	--
3/18	21.3	7.8	3.1	11.8	--
3/19	22.0	7.5	1.2	14.1	1.7
3/20	20.4	7.4	2.0	15.1	1.7
3/21	21.5	7.3	2.1	17.5	2.0
3/22	21.7	7.4	1.5	13.4	--
3/23	23.6	7.3	1.3	19.8	--
3/24	22.9	7.4	1.3	11.0	--
3/25	23.2	7.2	1.2	8.2	--
3/26	23.8	7.6	2.7	11.8	1.5
3/27	23.3	7.4	6.0	13.4	1.4
3/28	23.6	7.4	6.0	18.5	2.0
3/29	25.2	7.4	4.6	25.7	--
3/30	24.9	7.3	5.9	16.7	--
3/31	25.5	8.1	6.4	14.2	--
平均	22.8	7.3	2.4	15.8	1.8