

96年5月南部科學工業園區高雄園區污水處理廠放流水質

日期	Temp (°C)	pH	SS (mg/L)	COD (mg/L)	BOD <sub>5</sub> (mg/L)
5/1	27.6	6.9	2.6	11.9	3.5
5/2	25.5	7.1	2.2	9.4	2.0
5/3	26.2	7.0	2.1	7.1	2.5
5/4	24.9	7.0	3.4	12.8	--
5/5	24.1	7.1	2.2	9.5	--
5/6	23.9	7.0	5.5	10.6	--
5/7	24.9	6.8	1.0	7.9	--
5/8	23.8	6.8	1.6	14.2	--
5/9	25.6	7.0	1.6	N.D	1.7
5/10	26.1	6.8	1.6	9.4	2.0
5/11	25.8	6.8	1.4	10.9	1.7
5/12	26.2	6.8	3.0	16.4	--
5/13	27.0	7.0	7.3	18.7	--
5/14	26.4	7.3	2.9	11.7	--
5/15	27.3	7.1	2.3	N.D	2.5
5/16	27.1	7.1	2.0	13.3	4.4
5/17	26.7	7.1	1.0	11.1	1.7
5/18	26.7	7.0	0.5	5.6	--
5/19	26.0	7.3	2.2	6.4	--
5/20	25.0	7.1	1.0	7.7	--
5/21	22.6	7.0	1.2	12.9	--
5/22	26.5	6.8	0.9	18.5	2.4
5/23	26.0	6.5	0.8	11.1	2.1
5/24	26.4	6.6	0.4	5.6	2.3
5/25	26.7	6.6	0.5	5.7	--
5/26	27.6	6.8	4.0	13.8	--
5/27	27.3	8.1	0.8	6.5	--
5/28	26.5	6.8	0.9	13.8	--
5/29	27.4	6.7	0.8	11.2	1.9
5/30	27.3	6.8	1.0	9.0	--
5/31	26.3	6.8	0.8	9.7	--
平均	26.0	7.0	1.9	10.1	2.4