

96年7月南部科學工業園區高雄園區污水處理廠放流水質

日期	Temp (°C)	pH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
7/1	29.0	7.6	1.3	4.7	--
7/2	28.5	7.5	1.0	9.5	--
7/3	27.4	7.5	1.0	7.8	1.5
7/4	26.1	7.5	1.3	5.5	1.6
7/5	26.5	7.7	1.2	5.4	2.2
7/6	26.8	7.8	4.4	5.5	--
7/7	27.1	7.8	1.1	5.5	--
7/8	26.9	7.7	1.7	10.2	--
7/9	27.4	7.8	2.0	7.1	--
7/10	28.1	7.7	4.5	4.7	1.8
7/11	28.7	7.8	8.4	18.1	1.9
7/12	27.5	7.6	1.4	10.3	2.6
7/13	29.7	7.4	0.6	4.9	--
7/14	27.0	7.7	1.0	12.6	--
7/15	27.6	7.7	0.6	9.9	--
7/16	27.0	7.4	0.8	11.8	--
7/17	27.9	7.4	1.0	12.6	2.0
7/18	26.6	7.5	0.7	7.0	1.4
7/19	26.3	7.6	1.8	9.5	2.3
7/20	26.1	7.6	3.5	7.2	--
7/21	29.0	7.9	3.9	11.9	--
7/22	29.1	7.8	3.2	7.1	--
7/23	29.0	8.0	2.0	12.7	--
7/24	28.8	7.7	4.1	19.0	1.6
7/25	28.3	7.6	1.1	10.2	2.0
7/26	28.6	7.7	1.0	8.6	1.9
7/27	28.4	7.6	0.8	8.6	--
7/28	28.4	7.7	0.8	12.7	--
7/29	29.4	7.7	1.6	15.1	--
7/30	26.1	7.6	2.0	8.0	--
7/31	26.8	7.7	2.0	5.6	--
平均	27.7	7.7	2.0	9.3	1.9