

96 年 8 月南部科學工業園區高雄園區污水處理廠放流水質

日期	Temp (°C)	pH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
8/1	26.4	7.8	3.3	11.1	2.1
8/2	28.8	7.9	6.0	16.7	1.9
8/3	27.1	7.9	2.2	15.1	--
8/4	29.1	7.6	1.8	9.4	--
8/5	29.2	7.9	1.2	11.0	--
8/6	29.0	7.9	1.0	5.5	--
8/7	28.0	7.7	1.0	14.3	1.8
8/8	27.4	7.6	2.1	17.4	1.9
8/9	26.5	7.6	1.9	11.2	1.4
8/10	26.6	7.6	0.6	13.7	--
8/11	25.7	7.7	1.0	14.2	--
8/12	26.0	7.4	1.6	15.8	--
8/13	24.5	7.4	0.7	13.4	--
8/14	26.3	7.5	3.0	14.9	3.1
8/15	26.2	7.0	0.8	10.2	2.3
8/16	23.2	7.1	4.1	8.6	2.1
8/17	25.7	7.3	6.7	11.8	--
8/18	26.2	7.4	6.4	5.6	--
8/19	26.0	7.4	8.4	11.7	--
8/20	26.0	7.3	12.6	11.3	--
8/21	26.5	7.4	16.0	12.9	1.6
8/22	25.8	7.5	17.7	12.9	1.6
8/23	27.1	7.7	11.3	7.1	1.6
8/24	27.6	7.2	8.2	7.9	--
8/25	27.4	7.8	7.5	6.1	--
8/26	27.4	7.7	6.4	6.1	--
8/27	27.6	7.5	4.9	5.4	--
8/28	26.3	7.4	2.4	15.6	2.4
8/29	25.6	7.5	1.6	11.8	--
8/30	25.1	7.6	1.7	12.2	--
8/31	25.7	8.0	1.6	7.2	--
平均	26.6	7.6	4.7	11.2	2.0