

96 年 11 月南部科學工業園區高雄園區污水處理廠放流水質

日期	Temp (°C)	pH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
11/1	27.0	7.7	1.8	13.1	3.2
11/2	26.7	7.6	1.4	13.0	--
11/3	25.7	7.9	0.8	17.1	--
11/4	25.6	7.7	1.0	17.9	--
11/5	26.8	7.9	1.0	17.1	--
11/6	25.0	7.9	1.1	15.6	2.2
11/7	25.7	7.8	2.0	13.2	3.5
11/8	25.2	7.8	1.9	16.5	2.5
11/9	25.6	7.7	1.2	16.4	--
11/10	26.5	8.0	0.8	11.6	--
11/11	26.3	7.8	1.5	14.7	--
11/12	26.6	7.8	1.0	14.7	--
11/13	26.6	7.8	1.0	14.7	2.5
11/14	26.4	8.0	1.2	13.1	2.6
11/15	26.7	7.6	2.2	13.9	3.0
11/16	26.5	7.7	1.4	22.7	--
11/17	25.9	8.0	1.4	21.7	--
11/18	25.4	7.8	1.4	20.1	--
11/19	25.4	7.8	1.4	14.7	--
11/20	25.0	7.8	2.2	11.8	1.3
11/21	23.4	7.8	1.0	13.5	3.5
11/22	24.4	7.9	1.2	22.0	2.4
11/23	23.2	7.7	1.6	11.9	--
11/24	26.5	7.6	1.7	15.8	--
11/25	26.5	7.8	1.6	24.4	--
11/26	26.2	7.7	1.2	20.6	--
11/27	24.3	7.6	1.0	7.9	2.4
11/28	23.4	8.1	0.8	11.9	2.6
11/29	23.0	7.7	1.1	19.8	3.9
11/30	22.6	7.6	0.6	14.6	--
平均	25.5	7.8	1.3	15.9	2.7