

96 年 12 月南部科學工業園區高雄園區污水處理廠放流水質

日期	Temp (°C)	pH	SS (mg/L)	COD (mg/L)	BOD <sub>5</sub> (mg/L)
12/1	21.4	7.7	0.6	13.4	--
12/2	22.0	7.7	0.8	18.9	--
12/3	22.6	7.8	0.8	13.4	--
12/4	23.4	7.7	0.8	12.7	2.3
12/5	23.7	8.0	1.2	16.5	3.1
12/6	20.1	7.8	2.3	18.1	3.1
12/7	23.2	7.9	2.6	15.7	--
12/8	23.6	7.8	1.8	15.9	--
12/9	23.4	7.6	2.6	11.9	--
12/10	23.5	7.5	2.2	11.9	--
12/11	23.6	7.8	2.0	11.9	3.9
12/12	22.4	7.7	3.6	23.0	2.9
12/13	24.4	7.8	1.8	24.6	3.4
12/14	23.5	7.7	2.0	25.7	--
12/15	22.5	7.6	2.1	16.0	--
12/16	22.9	7.9	1.4	20.0	--
12/17	23.6	7.9	2.0	16.0	--
12/18	22.3	7.6	1.5	23.9	3.1
12/19	22.2	7.8	1.7	12.0	1.6
12/20	19.9	7.8	1.8	16.0	2.5
12/21	22.0	7.6	2.2	22.3	--
12/22	23.5	7.7	1.2	18.4	--
12/23	23.6	7.8	1.2	18.4	--
12/24	23.4	7.7	1.5	18.4	--
12/25	23.5	7.6	1.7	16	2.4
12/26	23.6	7.5	2.1	13.5	2.7
12/27	23.5	7.6	1.6	22.2	6.6
12/28	23.6	7.7	2.0	23.8	--
12/29	22.3	7.7	1.4	16.2	--
12/30	22.4	7.6	1.2	20.3	--
12/31	20.4	7.7	1.4	9.8	--
平均	22.8	7.7	1.7	17.3	3.1