

97 年 01 月南部科學工業園區高雄園區污水處理廠放流水質

日期	Temp (°C)	pH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
01/1	20.8	7.6	1.4	12.1	-
01/2	20.5	7.7	1.6	16.2	3.4
01/3	18.9	7.9	1.2	12.1	6.2
01/4	21.4	7.8	1.0	12.0	3.6
01/5	22.5	7.8	2.2	12.0	-
01/6	22.4	7.8	1.8	16.0	-
01/7	23.1	7.8	2.1	12.0	-
01/8	24.1	7.7	1.6	13.5	4.2
01/9	22.4	7.9	1.2	17.5	4.1
01/10	23.7	7.7	2.1	11.9	2.8
01/11	24.1	7.7	2.6	23.8	-
01/12	21.9	8.0	0.8	19.8	-
01/13	22.2	8.0	1.6	19.8	-
01/14	20.8	7.6	1.0	23.8	-
01/15	20.4	7.6	1.6	27.7	6.9
01/16	19.5	7.7	1.4	23.8	5.5
01/17	19.7	7.6	1.1	11.9	5.3
01/18	19.1	7.4	1.2	25.3	-
01/19	20.4	7.4	1.2	22.1	-
01/20	22.3	7.6	0.9	22.1	-
01/21	19.2	7.4	1.0	26.1	-
01/22	22.7	7.6	1.2	23.7	5.5
01/23	23.0	7.5	1.0	16.0	6.4
01/24	22.0	7.5	0.6	19.9	8.1
01/25	22.0	7.6	1.0	15.9	-
01/26	20.5	7.6	1.0	28.1	-
01/27	21.4	7.5	0.9	28.1	-
01/28	20.5	7.5	2.7	24.1	-
01/29	19.6	7.7	2.5	25.5	3.9
01/30	21.6	7.4	1.8	15.9	2.3
01/31	19.5	7.4	0.8	23.9	5.9
平均	21.4	7.6	1.4	19.4	4.9