

97 年 02 月南部科學工業園區高雄園區污水處理廠放流水質

日期	Temp (°C)	pH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
02/1	19.9	7.6	0.8	27.7	
02/2	18.4	7.5	1.8	16.1	
02/3	18.2	7.4	0.8	12.1	
02/4	18.4	7.5	1.6	12.1	
02/5	18.4	7.6	1.0	15.8	3.8
02/6	15.6	7.9	0.6	7.9	
02/7	16.0	7.9	1.1	19.7	
02/8	15.6	7.8	1.0	19.7	
02/9	15.7	7.8	0.8	19.7	
02/10	15.0	7.8	2.0	19.7	
02/11	16.9	7.8	0.8	23.6	
02/12	16.1	7.4	1.5	23.6	3.4
02/13	17.2	7.6	1.1	17.3	2.5
02/14	15.5	7.7	2.1	27.6	3.5
02/15	15.4	7.7	2.4	25.9	
02/16	18.5	7.9	1.2	27.9	
02/17	19.0	7.8	2.1	27.9	
02/18	21.4	7.8	1.2	27.9	
02/19	18.4	7.6	1.3	27.9	5.4
02/20	19.4	7.7	2.4	19.9	4.6
02/21	19.3	7.8	2.2	27.8	7.0
02/22	20.3	7.6	2.6	27.8	
02/23	19.6	7.8	1.9	17.6	
02/24	19.7	7.9	1.4	21.6	
02/25	18.9	7.6	1.1	29.6	
02/26	19.8	7.6	0.8	16.0	4.3
02/27	17.3	7.7	1.0	20.0	5.7
02/28	18.2	7.7	1.2	12.0	
02/29	17.2	7.6	2.4	20.0	3.2
平均	17.9	7.7	1.5	21.1	4.3