

97 年 05 月南部科學工業園區高雄園區污水處理廠放流水質

日期	Temp (°C)	pH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
05/1	26.1	7.4	2.1	13.3	2.6
05/2	25.9	7.4	1.9	11.8	
05/3	29.2	7.4	2.0	14.2	
05/4	29.1	7.2	1.4	12.6	
05/5	24.8	7.3	2.1	10.2	
05/6	25.2	7.3	1.6	11.8	1.7
05/7	25.8	7.2	2.4	14.9	1.8
05/8	28.5	7.4	1.4	12.5	1.8
05/9	25.6	7.1	1.4	9.4	
05/10	25.0	7.1	0.8	14.4	
05/11	27.2	7.5	1.0	17.7	
05/12	27.1	7.4	1.4	9.6	
05/13	26.7	7.4	0.8	14.2	1.7
05/14	27.0	7.5	1.0	14.2	1.5
05/15	27.4	7.2	1.4	9.5	1.6
05/16	27.1	7.1	1.0	7.1	
05/17	27.1	7.0	0.9	7.0	
05/18	27.4	7.0	0.8	9.4	
05/19	27.3	7.1	0.6	10.2	
05/20	26.4	7.4	1.4	12.5	2.0
05/21	27.1	7.1	0.8	8.6	1.5
05/22	26.7	6.9	0.6	6.2	1.8
05/23	26.8	7.1	0.6	10.2	
05/24	25.8	7.0	1.2	12.5	
05/25	26.2	7.2	1.5	14.8	
05/26	25.2	7.7	0.8	18.7	
05/27	25.7	7.1	1.0	14.0	1.7
05/28	27.0	7.2	1.2	9.4	1.6
05/29	25.2	7.2	1.2	12.4	1.6
05/30	28.0	7.2	1.9	15.5	
05/31	26.9	7.2	1.9	12.3	
平均	26.7	7.2	1.3	12.0	1.8