

97 年 07 月南部科學工業園區高雄園區污水處理廠放流水質

| 日期 | Temp (°C) | pH | SS (mg/L) | COD (mg/L) | BOD ₅ (mg/L) |
|-------|-----------|-----|-----------|------------|-------------------------|
| 07/1 | 27.0 | 7.5 | 1.0 | 7.9 | 2.3 |
| 07/2 | 27.5 | 7.5 | 1.9 | 11.9 | 1.9 |
| 07/3 | 27.3 | 7.1 | 1.4 | 15.0 | 2.0 |
| 07/4 | 27.2 | 7.6 | 1.6 | 13.4 | |
| 07/5 | 26.2 | 7.6 | 2.2 | 7.0 | |
| 07/6 | 27.9 | 7.5 | 1.2 | 13.3 | |
| 07/7 | 26.2 | 7.6 | 1.0 | 9.4 | |
| 07/8 | 26.3 | 7.6 | 1.6 | 9.4 | 2.2 |
| 07/9 | 25.8 | 7.6 | 0.9 | 15.6 | 2.2 |
| 07/10 | 28.0 | 7.5 | 0.6 | 12.5 | 1.9 |
| 07/11 | 25.3 | 7.5 | 1.2 | 12.5 | |
| 07/12 | 27.1 | 7.4 | 2.2 | 9.4 | |
| 07/13 | 27.3 | 7.4 | 2.6 | 17.2 | |
| 07/14 | 27.4 | 7.5 | 2.0 | 10.2 | |
| 07/15 | 27.6 | 7.4 | 2.2 | 11.7 | 2.4 |
| 07/16 | 27.3 | 7.2 | 2.2 | 14.2 | 2.4 |
| 07/17 | 26.5 | 7.5 | 1.2 | 14.9 | 1.8 |
| 07/18 | 26.9 | 7.5 | 1.3 | 11.8 | |
| 07/19 | 23.8 | 7.4 | 2.2 | 14.1 | |
| 07/20 | 24.1 | 7.4 | 1.0 | 12.5 | |
| 07/21 | 28.7 | 7.4 | 0.8 | 14.9 | |
| 07/22 | 27.4 | 7.2 | 2.1 | 14.9 | 2.0 |
| 07/23 | 27.8 | 7.5 | 2.0 | 7.0 | 1.5 |
| 07/24 | 27.9 | 7.6 | 1.9 | 10.9 | 1.7 |
| 07/25 | 27.2 | 7.6 | 0.8 | 6.2 | |
| 07/26 | 26.9 | 7.0 | 0.8 | 4.7 | |
| 07/27 | 27.0 | 7.0 | 1.0 | 4.7 | |
| 07/28 | 27.0 | 7.0 | 0.6 | 4.7 | |
| 07/29 | 26.6 | 7.1 | 1.9 | 6.2 | 1.5 |
| 07/30 | 26.5 | 7.2 | 1.9 | 12.4 | 1.8 |
| 07/31 | 26.8 | 7.3 | 1.4 | 10.8 | 1.5 |
| 平均 | 26.9 | 7.4 | 1.5 | 11.0 | 1.9 |