

97 年 08 月南部科學工業園區高雄園區污水處理廠放流水質

日期	Temp (°C)	pH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
08/1	26.8	7.4	1.0	8.5	
08/2	27.0	7.3	1.6	7.0	
08/3	27.0	7.4	1.9	8.5	
08/4	26.7	7.5	2.2	7.0	
08/5	24.1	7.6	1.9	6.8	1.6
08/6	25.5	7.7	2.1	4.7	1.5
08/7	25.7	7.0	1.0	6.2	1.2
08/8	24.8	7.0	2.3	10.2	
08/9	27.0	7.1	2.2	14.1	
08/10	27.0	7.0	1.7	20.3	
08/11	27.0	7.1	1.4	10.2	
08/12	27.5	7.8	0.9	8.2	2.3
08/13	27.1	7.3	1.9	11.3	2.7
08/14	27.0	7.3	2.2	8.6	2.0
08/15	27.1	7.4	2.0	8.6	
08/16	27.1	7.6	2.0	7.0	
08/17	27.2	7.5	2.1	7.8	
08/18	27.3	7.2	2.0	3.2	
08/19	28.1	7.5	0.8	4.7	1.6
08/20	28.1	7.4	2.1	5.6	1.8
08/21	27.0	7.3	1.2	11.2	1.6
08/22	26.0	7.6	2.2	15.8	
08/23	27.4	7.2	1.9	9.5	
08/24	27.2	7.3	1.6	10.2	
08/25	27.2	7.1	1.4	9.5	
08/26	27.1	7.6	1.2	3.9	1.5
08/27	27.3	6.8	1.8	17.3	2.5
08/28	27.2	7.1	1.1	19.7	1.5
08/29	27.4	7.0	1.4	7.0	
08/30	27.6	7.3	1.9	14.8	
08/31	26.5	7.5	1.4	15.6	
平均	26.9	7.3	1.7	9.8	1.8