

97 年 09 月南部科學工業園區高雄園區污水處理廠放流水質

日期	Temp (°C)	pH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
09/1	25.8	7.3	1.8	10.2	
09/2	28.4	7.4	1.0	7.8	1.6
09/3	28.3	7.3	1.2	11.7	2.2
09/4	27.9	7.6	0.8	10.1	1.3
09/5	25.1	7.6	0.8	6.2	
09/6	27.3	6.9	1.3	9.3	
09/7	27.3	6.6	1.1	9.3	
09/8	27.4	7.6	2.0	10.1	
09/9	27.2	7.8	1.6	15.9	1.8
09/10	27.3	7.5	1.0	7.2	1.4
09/11	27.0	7.6	1.6	14.4	2.4
09/12	27.1	7.4	1.4	12.8	
09/13	26.8	7.6	1.2	12.7	
09/14	24.7	7.4	1.3	13.5	
09/15	26.4	7.6	1.5	9.5	
09/16	26.4	7.3	2.1	12.7	2.0
09/17	26.8	7.4	1.6	18.2	2.4
09/18	27.7	7.4	1.8	11.9	2.0
09/19	25.7	7.9	1.9	14.2	
09/20	27.1	7.6	2.1	14.3	
09/21	27.0	7.6	1.6	9.5	
09/22	27.4	7.2	1.6	11.9	
09/23	26.9	7.6	1.8	15.8	3.2
09/24	27.2	7.1	1.6	11.1	2.5
09/25	27.2	7.4	1.1	11.9	2.1
09/26	27.2	7.4	1.0	11.1	
09/27	27.1	7.6	2.0	12.8	
09/28	27.0	7.6	2.7	12.0	
09/29	26.7	7.5	2.2	15.2	
09/30	25.2	7.6	1.3	9.6	1.3
平均	26.9	7.4	1.5	11.8	2.0