

97 年 10 月南部科學工業園區高雄園區污水處理廠放流水質

日期	Temp (°C)	pH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
10/1	25.3	7.4	1.0	8.7	2.0
10/2	25.1	7.4	2.4	12.7	1.5
10/3	25.7	7.5	1.0	8.0	
10/4	27.4	7.7	1.6	7.2	
10/5	27.4	7.6	1.0	7.2	
10/6	27.1	7.7	1.0	7.2	
10/7	27.0	7.8	1.8	10.4	1.9
10/8	27.0	7.6	1.0	9.2	1.3
10/9	26.9	7.8	1.0	10.2	2.2
10/10	25.4	7.8	1.4	11.1	
10/11	26.5	8.0	1.2	7.1	
10/12	27.4	7.7	0.8	12.7	
10/13	25.6	7.7	1.4	7.7	
10/14	27.8	7.8	0.8	6.4	1.5
10/15	25.7	7.7	2.2	5.5	1.6
10/16	24.9	7.8	0.8	11.1	1.9
10/17	25.9	7.7	1.2	10.3	
10/18	26.9	7.6	1.0	10.3	
10/19	27.0	7.6	1.0	9.5	
10/20	26.9	7.5	1.7	11.8	
10/21	26.7	7.4	1.2	7.1	2.4
10/22	26.9	7.6	1.4	7.9	2.2
10/23	26.9	7.4	0.8	13.4	2.1
10/24	26.9	7.6	1.0	16.5	
10/25	26.0	7.6	1.0	10.1	
10/26	26.0	7.5	1.0	12.0	
10/27	26.8	7.6	1.4	16.5	
10/28	25.6	7.7	1.0	18.6	1.6
10/29	25.9	7.7	1.3	12.3	2.4
10/30	27.1	7.4	1.6	13.9	2.0
10/31	26.3	7.3	1.0	13.3	
平均	26.5	7.6	1.2	10.5	1.9