

97 年 11 月南部科學工業園區高雄園區污水處理廠放流水質

日期	Temp (°C)	pH	SS (mg/L)	COD (mg/L)	BOD <sub>5</sub> (mg/L)
11/1	25.6	7.6	1.0	8.8	
11/2	27.2	7.7	1.2	11.2	
11/3	27.7	7.3	1.2	6.4	
11/4	27.5	7.4	1.2	12.8	2.1
11/5	27.0	7.4	1.0	16.0	2.6
11/6	27.0	7.4	1.5	19.2	3.5
11/7	27.0	7.4	1.6	12.8	
11/8	24.8	7.5	1.6	10.4	
11/9	24.4	7.4	1.9	15.1	
11/10	24.4	7.5	1.4	12.0	
11/11	23.8	7.4	1.4	11.1	3.4
11/12	24.0	7.3	1.0	14.2	3.3
11/13	23.8	7.3	1.8	11.9	2.6
11/14	24.7	7.2	1.1	12.0	
11/15	26.7	7.4	1.9	11.2	
11/16	26.9	7.1	1.8	14.3	
11/17	26.9	7.3	1.4	26.3	
11/18	26.7	7.3	1.0	14.3	3.3
11/19	26.6	7.2	1.2	11.2	2.6
11/20	26.6	7.2	1.2	6.4	1.7
11/21	26.8	7.2	1.2	19.2	
11/22	25.2	7.2	1.2	16.0	
11/23	24.2	7.2	1.0	12.8	
11/24	25.6	7.2	1.0	18.4	
11/25	24.1	7.0	0.8	16.7	3.6
11/26	23.8	7.3	0.8	12.1	3.2
11/27	23.9	7.2	1.1	9.3	2.6
11/28	22.7	7.3	1.2	7.9	
11/29	26.8	7.3	2.0	11.9	
11/30	26.7	7.3	1.2	7.9	
平均	25.6	7.3	1.3	13.0	2.9