

98 年 03 月南部科學工業園區高雄園區污水處理廠放流水質

日期	Temp (°C)	pH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
03/01	24.8	7.5	0.8	13.0	
03/02	24.5	7.3	1.8	5.5	
03/03	24.3	7.5	1.8	6.0	1.7
03/04	24.2	7.4	1.4	5.5	1.8
03/05	24.6	7.4	1.6	9.9	2.0
03/06	24.4	7.4	1.9	9.2	
03/07	21.9	7.4	1.2	4.8	
03/08	22.1	7.4	2.0	4.0	
03/09	22.8	7.4	1.4	6.2	
03/10	22.1	7.5	0.6	8.5	2.8
03/11	23.0	7.4	1.4	8.1	2.1
03/12	22.8	7.5	2.6	11.5	3.7
03/13	23.3	7.5	1.8	11.2	
03/14	19.2	7.8	1.2	7.2	
03/15	19.1	7.8	1.5	10.4	
03/16	19.7	7.7	1.2	10.7	
03/17	22.7	7.4	1.3	14.4	2.7
03/18	23.4	7.4	1.9	11.2	2.4
03/19	23.9	7.6	1.9	12.0	4.8
03/20	24.0	7.7	2.2	12.3	
03/21	23.1	7.7	2.6	8.0	
03/22	23.2	7.7	2.2	6.4	
03/23	26.6	7.7	2.2	12.5	
03/24	24.0	7.7	2.4	10.1	1.9
03/25	23.7	7.8	2.5	17.1	5.7
03/26	24.4	7.6	2.4	15.7	5.1
03/27	24.4	7.6	1.6	11.0	
03/28	24.2	7.6	1.6	12.0	
03/29	24.0	7.6	2.0	10.4	
03/30	23.7	7.4	1.8	10.4	
03/31	23.6	7.6	0.8	12.9	
平均	23.3	7.5	1.7	9.9	3.1