

98 年 04 月南部科學工業園區高雄園區污水處理廠放流水質

日期	Temp (°C)	pH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
04/01	23.6	7.6	1.6	15.1	3.7
04/02	21.6	7.5	1.4	11.1	3.8
04/03	24.0	7.5	1.8	12.7	
04/04	22.8	7.4	1.9	9.6	
04/05	22.8	7.5	0.8	11.2	
04/06	23.9	7.5	1.4	9.6	
04/07	23.8	7.5	1.0	9.6	4.1
04/08	24.8	7.4	1.4	9.6	2.7
04/09	24.0	7.5	1.5	7.2	2.2
04/10	24.4	7.3	1.6	8.9	
04/11	25.7	7.4	1.4	9.6	
04/12	26.0	7.4	1.0	11.2	
04/13	26.1	7.6	1.8	8.0	
04/14	25.3	7.5	1.2	9.6	3.9
04/15	25.7	7.7	1.0	7.9	3.4
04/16	23.7	7.2	1.0	11.1	3.2
04/17	26.7	7.3	0.8	8.8	
04/18	24.1	7.5	0.9	8.6	
04/19	24.2	7.5	0.8	7.8	
04/20	27.5	7.5	1.0	8.6	
04/21	25.6	7.6	1.2	7.8	3.3
04/22	27.2	7.4	1.0	11.0	3.8
04/23	25.9	7.2	1.0	11.0	5.1
04/24	25.9	7.4	0.8	9.6	
04/25	26.5	7.3	0.7	8.8	
04/26	25.2	7.2	1.0	9.6	
04/27	25.5	7.3	0.8	8.0	
04/28	24.6	7.6	1.4	11.2	3.5
04/29	25.2	7.3	1.2	10.5	3.1
04/30	26.0	7.5	0.6	10.5	3.8
平均	24.9	7.4	1.2	9.8	3.5