

98 年 06 月南部科學工業園區高雄園區污水處理廠放流水質

日期	Temp (°C)	pH	SS (mg/L)	COD (mg/L)	BOD <sub>5</sub> (mg/L)
06/01	29.0	7.3	1.0	10.4	
06/02	28.2	7.1	0.6	12.0	2.5
06/03	28.0	7.3	1.0	7.2	2.3
06/04	27.6	7.5	1.2	10.4	3.0
06/05	28.7	7.5	1.0	8.8	
06/06	28.5	7.2	0.8	8.0	
06/07	31.0	7.2	0.8	8.0	
06/08	30.4	7.2	0.9	12.0	
06/09	30.7	7.4	0.8	12.0	2.2
06/10	31.2	7.3	1.0	8.8	1.8
06/11	28.3	7.5	0.6	10.4	2.0
06/12	25.6	7.1	1.0	10.4	
06/13	27.8	7.0	0.8	12.0	
06/14	27.6	7.4	0.5	13.6	
06/15	28.3	7.3	0.9	12.8	
06/16	26.4	7.4	1.0	11.2	3.6
06/17	27.3	7.2	1.0	9.6	2.4
06/18	27.6	7.0	0.6	8.8	2.6
06/19	26.8	7.4	1.0	13.6	
06/20	28.0	7.3	0.8	11.8	
06/21	29.0	7.4	1.2	13.4	
06/22	28.6	7.3	1.1	10.6	
06/23	28.8	7.2	0.9	13.4	3.1
06/24	30.4	7.2	0.8	15.2	2.8
06/25	30.9	7.1	1.0	12.0	2.4
06/26	31.4	7.1	0.8	10.4	
06/27	29.0	7.0	1.0	10.4	
06/28	29.0	7.1	1.0	9.6	
06/29	29.8	7.2	1.0	9.6	
06/30	29.3	7.2	1.0	8.8	
平均	28.8	7.2	0.9	10.8	2.6