

98 年 07 月南部科學工業園區高雄園區污水處理廠放流水質

日期	Temp (°C)	pH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
07/01	29.6	7.2	0.6	10.4	3.8
07/02	30.0	7.3	0.8	8.8	3.7
07/03	28.0	7.4	0.6	9.6	
07/04	31.4	7.2	0.8	12.7	
07/05	31.4	7.2	0.6	12.7	
07/06	31.5	7.1	1.0	11.1	
07/07	31.4	7.2	1.0	9.4	3.2
07/08	31.3	7.0	1.2	9.4	3.3
07/09	29.3	7.2	1.2	7.9	3.0
07/10	31.5	7.2	1.0	11.3	
07/11	29.2	7.3	0.8	10.4	
07/12	30.3	7.0	0.9	9.6	
07/13	28.7	7.3	1.0	11.2	
07/14	29.0	7.5	0.8	8.0	2.8
07/15	29.0	7.3	0.9	9.6	3.5
07/16	29.2	7.2	0.8	12.0	3.9
07/17	30.0	7.1	0.7	8.8	
07/18	30.8	7.4	0.6	8.4	
07/19	31.1	7.3	0.9	9.2	
07/20	31.6	7.3	0.8	8.8	
07/21	31.8	7.1	0.7	10.4	3.8
07/22	31.8	7.0	1.0	11.6	3.5
07/23	32.0	7.1	1.2	16.0	4.7
07/24	31.9	7.1	0.9	13.5	
07/25	28.5	7.2	0.9	13.5	
07/26	27.6	7.4	0.9	15.9	
07/27	28.2	7.6	1.1	13.9	
07/28	29.6	7.3	1.0	17.5	5.0
07/29	29.7	7.1	1.0	7.9	3.0
07/30	29.8	7.3	0.8	9.5	3.5
07/31	29.6	7.3	0.6	8.0	
平均	30.2	7.2	0.9	10.9	3.6