

98 年 10 月南部科學工業園區高雄園區污水處理廠放流水質

日期	Temp (°C)	pH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
10/01	29.6	7.3	1.1	17.4	7.1
10/02	29.3	7.3	1.3	16.9	
10/03	27.8	7.2	1.2	21.6	
10/04	27.4	7.3	1.2	20.0	
10/05	27.9	7.2	1.5	22.0	
10/06	27.3	7.2	1.4	16.8	7.7
10/07	26.9	7.1	1.3	14.3	6.1
10/08	26.7	7.2	1.2	15.9	7.1
10/09	27.9	7.2	1.1	19.9	
10/10	29.4	7.4	1.1	20.3	
10/11	29.4	7.4	1.0	20.3	
10/12	29.1	7.3	1.0	21.0	
10/13	29.6	7.2	1.5	18.2	8.2
10/14	28.4	7.4	1.1	17.8	8.0
10/15	28.1	7.4	1.1	14.2	6.2
10/16	28.1	7.2	1.2	15.8	
10/17	27.8	7.2	1.0	18.5	
10/18	27.8	7.2	1.2	17.7	
10/19	27.7	7.3	1.7	20.9	
10/20	26.9	7.2	1.3	19.2	8.5
10/21	26.1	7.2	1.5	18.7	8.4
10/22	26.1	7.1	1.9	17.6	8.2
10/23	26.7	7.0	1.9	21.9	
10/24	27.1	7.4	1.7	22.3	
10/25	27.0	7.2	1.8	23.1	
10/26	27.2	7.2	1.6	28.7	
10/27	26.9	7.2	1.8	23.9	10.9
10/28	26.6	7.2	1.2	28.6	12.7
10/29	27.1	7.1	1.6	29.3	13.1
10/30	27.0	7.2	1.8	26.5	
10/31	24.8	7.3	1.0	27.7	
平均	27.6	7.2	1.4	20.5	8.6