

99 年 03 月南部科學工業園區高雄園區污水處理廠放流水質

日期	Temp (°C)	pH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
03/01	27.6	6.8	1.6	17.7	
03/02	27.5	7.2	1.4	19.7	8.1
03/03	27.7	7.0	1.4	18.1	7.8
03/04	27.4	6.9	1.8	18.1	7.5
03/05	25.5	6.9	1.2	17.7	
03/06	25.2	6.9	1.2	17.3	
03/07	25.7	6.9	1.3	18.9	
03/08	24.9	7.0	1.9	18.5	
03/09	23.1	7.1	1.3	16.1	7.4
03/10	20.5	7.0	1.1	15.6	6.0
03/11	20.7	6.8	1.4	13.5	6.2
03/12	23.2	7.0	1.3	16.0	
03/13	26.4	7.4	1.5	16.7	
03/14	26.6	7.3	1.3	17.5	
03/15	26.5	7.2	1.7	17.5	
03/16	25.1	7.2	1.5	17.0	7.0
03/17	26.2	7.3	1.4	17.3	6.8
03/18	23.8	7.0	1.2	16.5	8.7
03/19	26.1	7.1	1.4	17.6	
03/20	25.3	7.4	1.2	16.6	
03/21	25.5	7.3	1.2	16.6	
03/22	25.7	7.2	1.3	16.6	
03/23	25.2	7.3	1.6	15.4	6.3
03/24	26.8	7.2	1.4	17.8	7.2
03/25	25.2	7.2	1.7	19.0	9.2
03/26	22.7	7.2	1.5	18.2	
03/27	26.6	7.3	1.6	18.2	
03/28	26.5	7.2	1.6	17.4	
03/29	26.6	6.9	1.5	19.0	
03/30	26.3	7.2	1.6	17.0	7.2
03/31	26.6	6.9	1.5	17.8	7.1
平均	25.4	7.1	1.4	17.3	7.3