

99 年 04 月南部科學工業園區高雄園區污水處理廠放流水質

日期	Temp (°C)	pH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
04/01	26.6	6.9	1.4	18.5	7.5
04/02	26.7	7.1	1.4	20.9	
04/03	25.4	7.2	1.2	20.9	
04/04	25.9	7.2	1.3	20.1	
04/05	25.6	7.2	1.4	16.8	
04/06	24.8	7.1	1.6	20.1	7.8
04/07	24.1	7.0	1.4	15.6	6.8
04/08	25.4	7.1	1.6	18.2	8.1
04/09	24.8	7.1	2.3	17.0	
04/10	26.8	7.2	1.1	20.6	
04/11	26.7	7.2	1.7	19.4	
04/12	26.8	7.1	1.5	20.6	
04/13	26.2	7.2	1.8	20.6	7.9
04/14	26.3	7.3	1.4	18.9	7.9
04/15	25.6	7.3	1.5	19.3	7.8
04/16	24.2	7.2	1.3	18.2	
04/17	24.9	7.2	1.9	17.1	
04/18	25.2	7.2	1.5	21.6	
04/19	25.2	7.1	1.7	16.3	
04/20	26.4	7.2	1.4	16.8	6.6
04/21	27.3	7.0	1.4	18.4	7.3
04/22	27.6	7.2	1.3	14.4	6.0
04/23	25.6	7.0	2.0	13.2	
04/24	27.0	6.8	1.8	14.8	
04/25	27.2	6.9	1.2	17.2	
04/26	26.7	6.9	1.9	13.2	
04/27	27.1	7.1	2.0	12.3	5.4
04/28	27.0	6.9	2.0	14.2	6.0
04/29	26.8	7.0	1.9	13.0	5.8
04/30	26.6	7.0	1.6	17.4	
平均	26.1	7.1	1.6	17.5	7.0