

99 年 06 月南部科學工業園區高雄園區污水處理廠放流水質

日期	Temp (°C)	pH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
06/01	27.8	7.0	1.8	16.4	6.4
06/02	27.5	7.2	1.9	14.4	5.8
06/03	26.8	7.2	1.5	16.3	6.1
06/04	27.3	7.1	1.5	15.5	
06/05	27.6	7.2	1.6	16.0	
06/06	27.6	7.1	1.8	17.7	
06/07	27.6	7.0	1.9	16.9	
06/08	27.4	7.0	1.8	14.3	5.9
06/09	27.3	7.1	1.7	13.5	5.5
06/10	27.2	7.2	1.6	15.5	5.8
06/11	26.9	7.2	2.0	14.3	
06/12	27.2	7.2	1.9	15.8	
06/13	27.2	7.2	2.0	16.3	
06/14	27.6	7.2	1.9	16.7	
06/15	27.2	7.1	2.3	17.9	6.9
06/16	27.6	7.2	1.8	18.6	
06/17	28.6	7.0	2.2	20.2	7.5
06/18	28.6	6.9	1.8	18.3	
06/19	27.9	7.2	1.9	17.4	
06/20	28.0	7.1	1.8	18.2	
06/21	27.8	7.0	1.9	18.2	
06/22	27.7	6.9	2.0	17.8	7.0
06/23	27.6	7.1	1.5	17.8	6.7
06/24	27.4	7.2	2.1	20.4	7.0
06/25	26.5	7.2	1.4	18.5	
06/26	28.6	7.1	1.7	17.4	
06/27	28.9	7.1	1.9	16.6	
06/28	29.0	6.9	1.7	16.6	
06/29	29.0	7.0	1.6	15.4	6.4
06/30	29.3	6.8	1.5	14.9	5.9
平均	27.8	7.1	1.8	16.8	6.4