

99 年 07 月南部科學工業園區高雄園區污水處理廠放流水質

日期	Temp (°C)	pH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
07/01	29.7	7.0	1.3	16.5	6.0
07/02	27.7	7.2	2.1	17.5	
07/03	27.7	7.0	1.3	17.9	
07/04	27.7	7.1	1.2	16.3	
07/05	27.2	7.2	1.5	16.7	
07/06	27.5	7.2	1.6	17.9	6.8
07/07	27.7	7.0	1.9	17.6	6.8
07/08	27.5	7.1	1.8	17.3	6.6
07/09	27.6	7.0	2.0	17.5	
07/10	29.4	7.3	1.2	17.9	
07/11	29.6	7.3	1.9	18.7	
07/12	30.1	7.1	1.4	22.0	
07/13	30.1	7.1	1.1	18.2	6.7
07/14	27.8	7.2	1.9	17.8	6.9
07/15	27.6	7.1	1.8	17.2	6.5
07/16	29.6	7.0	1.2	17.8	
07/17	27.6	7.3	1.1	19.2	
07/18	27.6	7.2	2.0	18.4	
07/19	27.5	7.2	1.5	18.8	
07/20	27.5	7.1	1.4	17.3	6.8
07/21	27.5	6.9	2.0	17.0	6.7
07/22	27.4	6.9	1.5	16.8	6.6
07/23	27.4	7.1	1.9	16.6	
07/24	27.0	7.1	1.5	16.9	
07/25	28.6	7.0	1.8	17.7	
07/26	29.1	7.2	1.4	16.0	
07/27	28.3	7.1	1.0	15.8	5.9
07/28	28.6	7.1	1.7	14.6	5.6
07/29	27.5	7.0	2.0	16.5	6.3
07/30	27.3	7.1	1.2	16.2	
07/31	27.1	7.3	1.7	16.8	
平均	28.1	7.1	1.6	17.4	6.5