

99 年 09 月南部科學工業園區高雄園區污水處理廠放流水質

日期	Temp (°C)	pH	SS (mg/L)	COD (mg/L)	BOD <sub>5</sub> (mg/L)
09/01	26.5	7.1	1.7	11.4	4.5
09/02	26.8	7.0	1.3	11.5	4.5
09/03	27.1	7.2	1.8	10.2	
09/04	28.6	7.1	1.7	11.4	
09/05	28.7	7.2	1.9	12.2	
09/06	28.5	7.0	1.5	10.6	
09/07	27.4	7.0	1.3	10.6	3.8
09/08	28.2	7.0	1.8	11.4	4.0
09/09	27.6	7.1	1.5	11.4	4.3
09/10	27.3	7.0	1.2	11.8	
09/11	27.1	7.2	1.4	11.2	
09/12	27.0	7.2	1.7	11.2	
09/13	27.2	7.1	1.6	13.3	
09/14	26.9	7.0	1.7	13.2	5.3
09/15	26.9	7.1	2.0	11.2	4.4
09/16	26.8	7.2	1.4	11.4	4.6
09/17	28.4	7.2	1.9	11.0	
09/18	26.1	7.3	3.0	12.6	
09/19	25.4	7.2	4.5	10.1	
09/20	23.0	7.2	2.7	11.0	
09/21	23.4	7.3	1.5	11.8	4.6
09/22	25.3	7.3	2.0	11.4	
09/23	25.3	7.0	1.5	10.6	4.1
09/24	25.8	6.9	1.7	10.6	
09/25	26.9	7.2	1.6	10.5	
09/26	26.8	7.2	2.0	10.5	
09/27	26.7	7.2	1.3	10.9	
09/28	26.9	7.2	1.6	9.3	4.0
09/29	27.0	7.2	1.6	11.2	4.5
09/30	27.1	7.2	2.0	11.2	4.3
平均	26.8	7.1	1.8	11.2	4.4