

99 年 10 月南部科學工業園區高雄園區污水處理廠放流水質

日期	Temp (°C)	pH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
10/01	27.1	7.1	1.5	9.2	
10/02	28.4	7.1	1.2	9.7	
10/03	28.8	7.2	2.0	9.7	
10/04	28.4	7.2	1.3	8.8	
10/05	28.1	7.4	1.6	9.6	4.1
10/06	28.5	7.2	1.8	8.8	3.7
10/07	27.6	7.2	1.4	8.4	3.4
10/08	27.4	7.2	1.8	8.8	
10/09	27.1	7.2	1.9	9.5	
10/10	26.9	7.2	1.3	7.9	
10/11	26.8	7.2	1.8	7.9	
10/12	26.8	7.1	1.5	8.7	3.4
10/13	26.7	7.2	1.2	9.4	3.7
10/14	26.7	7.0	1.7	10.2	4.4
10/15	26.7	7.1	1.4	8.4	
10/16	27.2	7.1	1.7	9.2	
10/17	21.5	7.1	1.6	8.4	
10/18	27.3	7.0	1.5	8.4	
10/19	28.0	7.2	1.2	8.4	4.2
10/20	27.6	7.1	1.9	10.0	4.2
10/21	27.3	7.2	1.5	9.2	4.1
10/22	26.9	7.2	1.9	7.6	
10/23	26.7	7.1	1.2	8.4	
10/24	26.7	7.1	1.2	9.2	
10/25	26.7	7.1	1.8	8.0	
10/26	26.1	7.2	1.6	10.3	4.2
10/27	25.1	7.1	1.5	10.1	4.1
10/28	25.1	7.1	1.7	9.6	3.9
10/29	26.3	7.2	2.0	10.4	
10/30	24.3	7.2	2.0	13.2	
10/31	24.1	7.2	1.6	14.0	
平均	26.7	7.2	1.6	9.3	4.0