

101 年 07 月南部科學工業園區高雄園區污水處理廠放流水質

日期	Temp (°C)	pH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
07/01	27.3	7.0	2.6	15.6	
07/02	28.4	6.9	2.5	14.8	
07/03	28.1	6.8	2.7	17.2	6.8
07/04	27.7	6.8	2.9	17.6	7.1
07/05	27.6	6.8	2.6	18.0	7.4
07/06	27.6	6.8	2.5	17.6	
07/07	27.5	6.9	2.7	18.3	
07/08	27.6	6.9	3.3	19.9	
07/09	27.8	7.0	3.6	19.1	
07/10	27.8	6.9	2.8	17.8	7.4
07/11	29.9	6.9	3.0	18.6	8.4
07/12	28.6	7.0	2.6	18.1	7.2
07/13	28.8	6.9	2.3	17.1	
07/14	28.2	7.1	2.5	18.9	
07/15	28.2	7.0	2.4	20.1	
07/16	28.5	7.0	2.9	19.3	
07/17	28.6	6.9	2.7	18.8	7.3
07/18	28.4	6.8	2.4	19.2	7.4
07/19	28.6	6.7	2.4	20.9	8.7
07/20	28.8	6.8	2.2	20.0	
07/21	28.6	6.9	2.3	18.7	
07/22	28.7	6.9	2.8	20.3	
07/23	28.7	6.7	2.6	18.7	7.5
07/24	28.6	6.8	2.5	17.8	7.2
07/25	28.6	6.8	2.1	20.1	8.6
07/26	28.6	6.8	2.1	19.4	
07/27	28.8	6.9	2.0	20.3	
07/28	27.7	7.1	2.3	21.9	
07/29	27.5	6.9	2.1	19.4	
07/30	28.5	6.9	2.0	21.1	
07/31	27.8	6.8	1.9	18.6	7.2
平均值	28.3	6.9	2.5	18.8	7.6