

101 年 08 月南部科學工業園區高雄園區污水處理廠放流水質

日期	Temp (°C)	pH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
08/01	28.6	6.9	2.3	18.9	7.9
08/02	28.1	7.0	2.1	20.1	
08/03	28.8	7.0	3.0	20.8	8.2
08/04	28.8	7.0	3.2	20.9	
08/05	28.8	7.0	3.0	20.9	
08/06	28.8	6.9	3.2	21.3	
08/07	28.6	6.9	2.8	21.6	8.7
08/08	28.6	6.9	3.2	21.5	9.1
08/09	28.6	6.9	3.0	20.7	8.8
08/10	28.5	6.9	3.8	19.9	
08/11	28.4	7.0	3.0	21.2	
08/12	28.3	7.0	3.1	22.8	
08/13	28.3	6.8	3.0	19.1	
08/14	28.0	6.9	3.6	22.3	9.4
08/15	28.6	7.0	2.8	23.4	9.7
08/16	28.7	7.0	3.1	24.2	10.0
08/17	28.4	7.1	3.1	22.5	
08/18	27.6	7.1	3.4	24.8	
08/19	27.3	7.0	3.5	23.2	
08/20	27.5	7.0	3.6	22.3	
08/21	27.7	6.9	3.2	24.4	
08/22	27.9	6.9	3.5	22.9	9.3
08/23	27.5	7.0	3.4	24.5	9.7
08/24	27.2	7.2	3.6	25.3	8.9
08/25	28.0	7.2	3.8	19.5	
08/26	28.0	7.2	3.6	22.7	
08/27	27.6	7.0	3.6	21.1	
08/28	27.2	7.0	3.7	21.6	8.8
08/29	27.9	7.1	3.5	22.7	7.8
08/30	28.5	7.0	3.8	20.3	8.1
08/31	28.5	6.9	4.1	22.3	
平均值	28.2	7.0	3.3	21.9	8.9