

101 年 11 月南部科學工業園區高雄園區污水處理廠放流水質

日期	Temp (°C)	pH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
11/01	26.0	6.8	1.9	20.4	8.7
11/02	26.1	6.8	1.9	18.8	
11/03	26.5	6.8	1.7	18.0	
11/04	26.5	6.8	1.5	15.6	
11/05	26.3	6.9	1.3	16.0	
11/06	26.7	7.0	1.5	15.7	6.5
11/07	25.3	7.1	1.2	15.3	5.8
11/08	26.4	7.1	1.1	13.8	5.6
11/09	26.0	6.9	1.5	13.8	
11/10	27.9	6.9	1.1	12.9	
11/11	27.0	6.9	1.5	12.1	
11/12	27.6	6.8	1.2	12.1	
11/13	26.6	6.7	1.3	12.9	5.2
11/14	26.6	6.8	1.3	11.6	5.3
11/15	26.3	6.8	1.5	13.4	5.9
11/16	26.0	6.7	1.3	12.0	
11/17	26.1	6.9	2.0	14.0	
11/18	26.5	7.0	2.6	16.3	
11/19	26.4	6.9	2.6	14.0	
11/20	26.3	7.0	2.5	14.5	6.4
11/21	26.3	6.8	2.2	14.5	6.1
11/22	26.9	6.9	2.5	13.8	5.7
11/23	26.6	6.9	2.2	14.5	
11/24	26.4	7.0	1.4	14.9	
11/25	26.3	7.1	1.1	16.6	
11/26	26.1	6.9	2.1	14.9	
11/27	24.4	6.7	2.0	15.7	6.0
11/28	26.0	6.7	1.6	14.2	6.0
11/29	26.3	6.6	1.8	13.3	5.3
11/30	26.4	6.8	1.8	13.4	
平均值	26.4	6.9	1.7	14.6	6.0