

102 年 02 月南部科學工業園區高雄園區污水處理廠放流水質

日期	Temp (°C)	pH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
2/01	23.3	7.0	N.D.<2.5	15.8	
2/02	23.4	6.9	N.D.<2.5	14.2	
2/03	23.5	6.9	N.D.<2.5	15.6	
2/04	22.0	7.0	N.D.<2.5	12.9	
2/05	24.1	7.1	N.D.<2.5	14.5	
2/06	22.4	7.2	4.3	17.7	
2/07	24.3	7.4	N.D.<2.5	15.2	
2/08	24.6	7.1	N.D.<2.5	19.6	5.2
2/09	24.3	7.2	N.D.<2.5	18.0	
2/10	24.1	7.1	N.D.<2.5	16.4	
2/11	24.1	7.2	N.D.<2.5	18.7	
2/12	23.6	7.0	N.D.<2.5	15.2	
2/13	23.8	6.9	N.D.<2.5	17.5	
2/14	24.1	7.3	N.D.<2.5	16.7	
2/15	24.1	7.1	N.D.<2.5	17.5	
2/16	24.0	7.2	N.D.<2.5	14.4	
2/17	24.5	7.3	N.D.<2.5	15.6	
2/18	24.8	7.0	N.D.<2.5	15.8	
2/19	25.9	6.9	N.D.<2.5	16.4	
2/20	22.6	7.0	N.D.<2.5	14.7	5.2
2/21	23.5	7.0	N.D.<2.5	19.8	
2/22	24.6	7.0	N.D.<2.5	14.1	
2/23	24.3	7.0	N.D.<2.5	13.6	
2/24	24.3	7.0	N.D.<2.5	13.6	
2/25	24.1	6.9	N.D.<2.5	19.2	
2/26	24.9	6.9	2.7	18.6	
2/27	25.1	7.0	N.D.<2.5	19.0	7.7
2/28	25.3	6.9	N.D.<2.5	19.9	
平均值	24.1	7.1	3.5	16.6	6.0