

102 年 04 月南部科學工業園區高雄園區污水處理廠放流水質

日期	Temp (°C)	pH	SS (mg/L)	COD (mg/L)	BOD <sub>5</sub> (mg/L)
4/01	25.9	7.0	1.70	15.4	
4/02	25.9	6.9	1.25	13.5	3.3
4/03	24.1	7.1	1.25	15.0	6.4
4/04	24.3	7.2	1.80	17.4	
4/05	25.1	6.9	1.25	18.0	
4/06	24.8	7.0	1.90	17.8	
4/07	24.5	7.2	1.80	18.0	
4/08	24.2	6.9	1.60	15.1	
4/09	26.0	6.9	1.25	9.9	4.2
4/10	24.1	6.8	1.25	13.1	4.8
4/11	24.7	7.1	1.90	17.0	4.6
4/12	24.0	7.1	1.25	16.2	
4/13	24.3	7.0	1.25	18.0	
4/14	24.5	7.0	1.25	15.0	
4/15	24.4	6.9	1.80	16.0	
4/16	26.1	7.0	1.50	16.6	4.2
4/17	25.1	7.2	1.90	17.4	4.1
4/18	24.5	7.1	1.25	19.0	4.5
4/19	26.1	7.0	1.25	17.8	
4/20	25.4	6.9	1.25	18.7	
4/21	25.1	7.1	1.70	17.4	
4/22	25.9	7.0	1.25	16.6	
4/23	25.5	6.8	1.25	16.6	4.0
4/24	25.8	6.9	1.25	16.2	5.3
4/25	25.8	7.1	1.80	15.4	4.7
4/26	24.8	7.1	1.70	18.2	
4/27	24.6	7.0	1.30	16.2	
4/28	24.5	6.9	1.25	17.4	
4/29	24.7	6.8	1.60	18.2	
4/30	24.8	7.0	1.50	17.4	4.0
平均值	25.0	7.0	1.48	16.5	4.5