

96年9月南部科學工業園區高雄園區污水處理廠放流水質

日期	Temp (°C)	pH	SS (mg/L)	COD (mg/L)	BOD <sub>5</sub> (mg/L)
9/1	27.6	7.7	1.2	15.8	--
9/2	27.7	7.8	2.5	7.1	--
9/3	27.5	7.8	1.6	11.1	--
9/4	27.5	7.8	2.0	9.5	2.0
9/5	27.6	7.9	1.9	7.2	1.7
9/6	27.5	7.5	1.2	8.0	1.7
9/7	27.4	7.8	1.2	4.8	--
9/8	27.9	7.4	1.0	13.2	--
9/9	27.7	7.6	0.6	11.6	--
9/10	23.8	7.4	0.8	12.4	--
9/11	25.0	7.8	1.6	10.6	2.3
9/12	23.0	7.7	1.2	9.4	2.7
9/13	27.4	7.6	1.5	N.D	1.5
9/14	27.4	7.7	1.3	22.6	--
9/15	27.6	7.7	0.8	5.5	--
9/16	27.9	7.7	1.0	10.2	--
9/17	27.4	7.6	1.0	10.9	--
9/18	26.5	7.9	1.0	22.7	4.3
9/19	27.2	7.7	1.2	17.9	5.2
9/20	27.3	7.5	2.0	21.1	4.9
9/21	27.3	7.7	2.2	6.3	--
9/22	28.3	7.5	1.4	10.4	--
9/23	27.5	7.4	0.6	7.2	--
9/24	27.3	7.9	1.8	6.4	--
9/25	28.2	7.4	1.4	7.2	4.1
9/26	28.4	7.7	1.2	10.4	4.5
9/27	28.8	7.6	0.8	10.1	4.4
9/28	27.8	7.4	1.2	7.5	--
9/29	27.2	7.4	1.2	7.0	--
9/30	27.3	7.8	0.8	6.3	--
平均	27.2	7.6	1.8	10.7	3.3