

98 年 11 月南部科學工業園區高雄園區污水處理廠放流水質

日期	Temp (°C)	pH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
11/01	24.2	7.3	1.2	23.7	
11/02	25.2	7.2	1.0	21.3	
11/03	24.6	7.2	0.9	16.3	7.7
11/04	26.8	7.1	1.1	15.9	7.0
11/05	26.1	7.1	1.0	15.0	7.2
11/06	27.8	7.2	1.2	11.5	
11/07	27.2	7.4	1.0	16.6	
11/08	27.4	7.4	1.3	17.4	
11/09	28.1	7.3	1.1	15.4	
11/10	26.9	7.1	1.4	13.0	8.0
11/11	26.8	7.3	1.2	16.2	5.9
11/12	26.6	7.4	1.4	15.1	6.7
11/13	26.2	7.2	1.3	15.4	
11/14	24.4	6.9	1.5	16.8	
11/15	25.0	7.0	1.2	15.2	
11/16	26.6	7.1	1.6	17.2	
11/17	25.3	7.2	1.1	16.8	7.2
11/18	24.5	7.0	1.5	16.0	7.0
11/19	24.1	7.1	1.0	15.1	7.6
11/20	25.5	7.2	1.3	13.9	
11/21	25.9	7.0	1.4	15.5	
11/22	25.7	7.0	1.1	14.7	
11/23	25.2	7.2	1.0	19.1	
11/24	24.6	7.2	1.1	18.7	8.3
11/25	24.5	7.1	1.3	15.5	7.9
11/26	25.2	7.2	1.3	20.6	8.8
11/27	25.4	7.1	1.1	21.7	
11/28	24.3	7.2	1.2	17.2	
11/29	24.5	7.4	1.0	18.0	
11/30	24.4	7.2	1.4	19.6	
平均	25.6	7.2	1.2	16.8	7.4