

98 年 12 月南部科學工業園區高雄園區污水處理廠放流水質

日期	Temp (°C)	pH	SS (mg/L)	COD (mg/L)	BOD <sub>5</sub> (mg/L)
12/01	23.8	7.1	1.2	16.4	7.6
12/02	22.9	7.2	1.1	15.5	7.0
12/03	23.0	7.1	1.2	13.1	6.1
12/04	22.3	7.0	1.3	11.9	
12/05	24.7	7.2	1.0	13.3	
12/06	24.7	7.2	1.1	14.9	
12/07	24.6	7.2	1.2	15.7	
12/08	24.6	7.1	1.3	13.2	6.5
12/09	24.7	7.0	1.4	15.2	7.1
12/10	24.4	7.1	1.5	15.1	6.5
12/11	24.9	7.2	1.3	12.7	
12/12	23.6	7.5	1.1	14.7	
12/13	23.8	7.4	1.4	15.5	
12/14	23.6	7.3	1.5	17.1	
12/15	24.3	7.3	1.3	16.4	7.3
12/16	23.3	7.2	1.1	15.0	6.9
12/17	23.0	7.1	1.0	16.6	7.0
12/18	14.3	7.3	1.2	16.2	
12/19	19.4	7.5	0.9	15.4	
12/20	19.8	7.4	1.1	14.6	
12/21	19.5	7.4	1.2	15.4	
12/22	20.0	7.3	1.2	15.9	7.4
12/23	23.4	7.2	1.3	16.7	7.0
12/24	23.5	7.3	1.3	16.7	7.0
12/25	23.6	7.2	1.5	15.1	
12/26	16.9	7.3	1.3	16.0	
12/27	18.0	7.2	1.2	13.6	
12/28	20.3	7.2	1.4	14.0	
12/29	19.9	7.1	1.5	13.5	6.1
12/30	21.7	7.2	1.6	14.3	6.3
12/31	21.2	7.1	1.4	14.7	6.1
平均	22.2	7.2	1.3	15.0	6.8