

99 年 01 月南部科學工業園區高雄園區污水處理廠放流水質

日期	Temp (°C)	pH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
01/01	22.8	7.2	1.1	12.3	
01/02	23.0	7.2	0.9	11.5	
01/03	23.1	7.1	1.1	11.5	
01/04	23.2	7.2	1.2	11.9	
01/05	22.3	7.2	1.2	14.3	6.4
01/06	22.4	7.3	1.3	13.5	6.1
01/07	22.5	7.0	1.7	14.0	6.4
01/08	22.2	7.1	1.5	13.9	
01/09	21.3	7.4	1.2	12.7	
01/10	21.3	7.3	1.5	12.0	
01/11	22.3	7.3	1.4	14.3	
01/12	20.9	7.3	2.0	11.6	4.6
01/13	19.1	7.3	1.8	14.7	6.0
01/14	19.6	7.3	1.8	12.4	5.9
01/15	18.8	7.4	1.6	11.6	
01/16	23.2	7.2	2.1	12.4	
01/17	23.5	7.1	1.6	13.9	
01/18	23.1	7.2	1.9	13.4	
01/19	23.6	7.3	1.7	14.8	7.2
01/20	24.1	7.1	2.0	13.5	6.3
01/21	23.2	7.2	2.1	16.8	7.4
01/22	23.1	7.2	1.9	15.6	
01/23	22.1	7.3	1.9	14.8	
01/24	19.9	7.3	1.6	14.4	
01/25	21.8	7.1	1.3	13.2	
01/26	20.8	7.2	1.3	13.7	5.8
01/27	21.4	7.1	1.1	14.0	6.0
01/28	22.9	7.0	1.4	18.4	8.4
01/29	22.4	7.0	1.5	17.2	
01/30	25.8	6.8	1.3	18.0	
01/31	26.1	7.3	1.4	16.4	
平均	22.3	7.2	1.5	14.0	6.4