

99 年 02 月南部科學工業園區高雄園區污水處理廠放流水質

日期	Temp (°C)	pH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
02/01	25.7	7.2	1.3	16.8	
02/02	26.2	7.2	1.2	14.8	6.5
02/03	24.1	7.2	1.5	13.6	5.7
02/04	24.2	7.1	1.4	14.4	5.9
02/05	24.3	7.2	1.4	13.5	
02/06	23.8	7.3	1.7	11.5	
02/07	23.7	7.6	1.5	14.7	
02/08	23.3	7.1	1.6	15.5	
02/09	23.2	7.2	1.6	16.0	7.3
02/10	24.5	7.1	1.4	16.1	6.3
02/11	23.8	7.0	1.7	17.7	8.0
02/12	23.3	7.0	1.9	15.6	
02/13	25.0	7.4	1.5	14.5	
02/14	25.1	7.4	1.4	13.7	
02/15	25.0	7.4	1.8	15.3	
02/16	23.0	7.4	1.6	14.5	
02/17	22.8	7.1	1.8	16.5	
02/18	20.3	7.3	1.7	20.5	
02/19	19.8	7.4	1.6	19.7	
02/20	19.6	7.4	1.5	18.1	
02/21	19.9	7.4	1.5	20.5	
02/22	20.4	7.2	1.9	20.9	
02/23	20.7	7.1	1.3	17.4	7.1
02/24	22.2	7.1	1.2	19.7	7.8
02/25	23.8	7.0	1.4	16.2	7.6
02/26	24.1	7.0	1.3	16.9	
02/27	27.7	6.9	1.1	16.1	
02/28	27.5	6.9	1.3	16.9	
平均	23.5	7.2	1.5	16.3	6.9