

100 年 01 月南部科學工業園區高雄園區污水處理廠放流水質

日期	Temp (°C)	pH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
01/01	24.1	7.1	1.8	14.3	
01/02	24.1	7.1	2.0	15.1	
01/03	23.9	7.2	2.1	15.9	
01/04	23.6	7.0	1.4	15.5	6.1
01/05	23.4	7.0	2.0	13.9	6.0
01/06	23.1	7.0	1.8	13.5	5.9
01/07	22.6	7.2	1.9	14.3	
01/08	21.5	7.4	1.8	14.7	
01/09	20.6	7.2	1.5	13.9	
01/10	21.0	7.1	1.6	14.7	
01/11	21.4	7.3	1.9	13.5	6.2
01/12	21.5	7.2	2.0	14.7	5.7
01/13	21.9	7.2	1.8	15.8	6.5
01/14	21.9	7.2	1.6	19.4	
01/15	20.5	7.1	1.7	14.7	
01/16	20.7	7.1	1.5	14.0	
01/17	20.6	7.1	1.4	13.2	
01/18	22.3	7.1	1.6	15.1	5.6
01/19	21.8	7.1	2.0	15.1	6.9
01/20	22.1	7.1	1.9	14.7	6.1
01/21	20.5	7.2	2.2	15.8	
01/22	22.1	7.0	1.5	16.6	
01/23	22.2	7.1	1.7	15.5	
01/24	21.2	7.0	1.5	15.5	6.3
01/25	21.7	7.0	1.4	14.5	6.6
01/26	22.1	7.0	1.5	14.6	6.0
01/27	22.5	7.1	1.6	16.0	
01/28	22.4	7.1	1.9	16.3	
01/29	23.1	6.9	1.7	15.5	
01/30	23.2	6.9	1.4	14.7	
01/31	23.1	7.0	1.6	16.3	
平均值	22.2	7.1	1.7	15.1	6.2