

100 年 04 月南部科學工業園區高雄園區污水處理廠放流水質

日期	Temp (°C)	pH	SS (mg/L)	COD (mg/L)	BOD <sub>5</sub> (mg/L)
04/01	23.8	7.1	1.7	16.7	7.0
04/02	18.6	7.2	1.6	15.5	
04/03	19.6	7.2	1.8	16.3	
04/04	20.2	7.2	1.7	17.1	
04/05	20.6	7.2	1.7	16.3	
04/06	23.3	7.1	1.6	16.3	6.9
04/07	26.6	6.9	1.8	16.6	6.6
04/08	25.6	7.0	1.8	19.8	
04/09	22.8	7.1	1.7	20.1	
04/10	23.7	7.1	1.7	20.9	
04/11	27.9	7.1	1.7	21.7	
04/12	24.2	7.1	1.7	21.0	8.6
04/13	26.6	7.1	1.9	22.5	8.8
04/14	26.3	7.1	1.9	19.7	8.4
04/15	26.9	7.1	1.9	20.6	
04/16	25.9	7.2	1.9	18.5	
04/17	27.6	7.2	1.8	19.3	
04/18	27.0	7.2	1.9	18.5	
04/19	27.8	7.2	1.8	20.4	8.8
04/20	27.6	7.2	1.9	19.7	8.0
04/21	27.3	7.1	2.0	22.0	9.3
04/22	28.6	7.2	1.9	20.7	
04/23	26.8	7.3	1.9	21.5	
04/24	27.3	7.3	2.0	19.9	
04/25	27.9	7.3	1.9	22.3	
04/26	28.7	7.2	1.9	19.5	8.0
04/27	28.4	7.2	1.8	18.3	7.4
04/28	28.0	7.2	1.7	17.8	7.2
04/29	28.3	7.1	1.7	16.6	
04/30	28.8	6.9	1.8	16.7	
平均值	25.8	7.1	1.8	19.1	7.9