

100 年 06 月南部科學工業園區高雄園區污水處理廠放流水質

日期	Temp (°C)	pH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
06/01	28.9	7.2	1.9	17.0	7.2
06/02	28.3	7.2	2.0	17.0	7.1
06/03	27.3	7.2	1.8	17.3	7.1
06/04	30.7	7.3	1.5	17.3	
06/05	32.0	7.3	1.3	15.2	
06/06	31.3	7.2	1.6	16.8	
06/07	29.9	7.2	1.9	15.6	
06/08	31.0	7.2	1.7	16.2	6.6
06/09	31.2	7.2	1.5	15.3	6.1
06/10	30.4	7.2	1.7	14.0	5.9
06/11	27.0	7.1	1.6	15.9	
06/12	26.9	7.0	1.7	16.3	
06/13	27.0	7.0	1.4	15.5	
06/14	27.0	7.2	1.7	13.6	6.0
06/15	27.1	7.2	1.8	15.4	6.3
06/16	27.2	7.1	1.8	13.8	6.0
06/17	27.3	7.0	1.6	13.8	
06/18	28.7	7.1	1.4	15.0	
06/19	28.5	7.1	1.5	14.2	
06/20	29.3	7.2	1.8	14.2	
06/21	26.4	7.1	1.8	15.8	6.8
06/22	26.4	7.0	2.0	16.0	6.7
06/23	26.7	7.0	1.9	17.3	6.6
06/24	26.8	6.9	1.8	16.1	
06/25	26.6	7.0	1.7	17.9	
06/26	26.6	7.0	1.9	17.1	
06/27	26.5	7.0	1.4	19.5	
06/28	26.6	7.0	3.3	16.7	6.7
06/29	29.0	7.0	2.3	14.0	5.7
06/30	28.1	6.9	1.6	15.1	6.1
平均值	28.2	7.1	1.8	15.8	6.5