

100 年 07 月南部科學工業園區高雄園區污水處理廠放流水質

日期	Temp (°C)	pH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
07/01	28.7	6.9	1.8	16.3	
07/02	28.5	6.8	1.7	16.3	
07/03	28.5	6.8	2.0	15.5	
07/04	28.3	6.9	1.4	13.9	
07/05	29.5	6.9	1.7	14.9	6.4
07/06	29.4	6.9	1.5	13.6	5.7
07/07	28.0	7.0	2.1	13.9	5.6
07/08	27.9	6.9	1.7	16.6	
07/09	28.5	6.9	1.9	15.9	
07/10	28.5	6.9	2.0	15.1	
07/11	28.5	6.9	1.6	16.6	
07/12	29.5	6.9	1.7	18.1	7.1
07/13	28.4	7.1	2.0	16.2	6.3
07/14	27.4	7.0	1.8	15.8	6.7
07/15	27.2	6.9	2.0	16.6	
07/16	27.6	6.8	1.7	16.1	
07/17	27.8	6.9	1.9	14.9	
07/18	27.4	7.0	2.0	14.1	
07/19	28.0	7.0	1.9	15.3	6.9
07/20	27.4	6.8	1.8	16.1	6.4
07/21	28.1	7.0	1.6	20.2	7.9
07/22	27.4	6.9	1.4	25.0	
07/23	28.2	6.9	1.6	30.1	
07/24	28.7	6.9	1.3	34.1	
07/25	29.6	6.9	1.7	35.7	
07/26	29.3	7.0	1.5	38.1	15.5
07/27	28.2	7.1	1.8	35.8	14.1
07/28	28.8	7.2	1.9	27.8	11.2
07/29	29.9	6.9	1.7	42.4	
07/30	29.8	6.9	1.5	40.1	
07/31	30.2	7.0	1.3	36.2	
平均值	28.5	6.9	1.7	21.8	8.3