

100 年 08 月南部科學工業園區高雄園區污水處理廠放流水質

日期	Temp (°C)	pH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
08/01	30.4	6.9	1.7	14.9	
08/02	28.9	6.9	1.4	17.8	6.8
08/03	28.3	6.9	1.7	15.0	
08/04	30.5	6.9	1.3	17.1	6.9
08/05	27.4	6.8	2.0	16.6	6.3
08/06	30.0	6.8	1.7	17.6	
08/07	30.4	6.9	1.9	19.2	
08/08	29.7	6.8	1.5	18.8	
08/09	29.8	6.9	1.6	20.5	7.9
08/10	28.3	7.0	1.8	25.3	9.8
08/11	28.2	7.1	1.5	24.2	10.6
08/12	26.7	7.2	1.7	23.6	
08/13	29.3	7.2	1.4	26.3	
08/14	28.9	7.2	1.6	25.5	
08/15	29.0	7.2	1.6	27.9	
08/16	28.9	7.1	1.9	26.5	11.3
08/17	28.8	7.1	1.7	24.8	9.8
08/18	28.6	7.2	2.3	25.5	9.6
08/19	29.7	7.5	1.9	21.3	
08/20	30.0	7.5	1.6	21.4	
08/21	30.4	7.5	1.7	20.6	
08/22	30.2	7.3	1.9	21.0	
08/23	30.1	7.2	1.7	19.4	8.1
08/24	30.6	7.5	2.1	16.6	6.8
08/25	29.9	7.5	2.2	16.2	7.1
08/26	30.5	7.5	1.6	16.6	
08/27	28.4	7.5	2.4	17.0	
08/28	28.1	7.5	2.0	15.4	
08/29	25.4	7.5	2.5	14.6	
08/30	26.5	7.5	2.9	14.2	5.8
08/31	28.1	7.4	2.4	16.5	6.6
平均值	29.0	7.2	1.8	19.6	8.1