

100 年 10 月南部科學工業園區高雄園區污水處理廠放流水質

日期	Temp (°C)	pH	SS (mg/L)	COD (mg/L)	BOD <sub>5</sub> (mg/L)
10/01	27.1	7.2	1.7	16.4	
10/02	26.9	7.3	1.8	16.4	
10/03	27.4	7.2	1.8	17.6	
10/04	26.9	7.3	2.0	17.2	
10/05	26.9	7.1	2.1	16.4	6.8
10/06	27.5	7.1	1.9	15.1	6.3
10/07	27.4	7.1	2.1	13.1	5.4
10/08	27.2	7.0	2.0	14.4	
10/09	27.4	7.0	2.0	13.6	
10/10	27.1	7.0	2.1	14.4	
10/11	27.3	7.2	1.8	14.8	6.7
10/12	27.8	7.2	2.1	13.2	5.4
10/13	27.1	7.2	1.8	14.3	5.8
10/14	27.5	7.1	2.2	15.9	
10/15	26.5	7.3	1.6	15.0	
10/16	26.5	7.3	1.8	14.2	
10/17	26.7	7.3	1.7	13.0	
10/18	27.9	7.2	1.8	14.2	5.5
10/19	27.1	7.2	1.7	13.0	5.6
10/20	27.1	7.1	1.6	13.4	5.4
10/21	27.1	7.1	1.7	12.2	
10/22	26.2	7.1	1.7	12.4	
10/23	26.9	7.1	1.9	11.6	
10/24	27.2	7.2	1.9	11.2	
10/25	28.5	7.1	1.6	10.8	4.7
10/26	27.6	7.2	1.6	11.6	4.5
10/27	26.9	7.2	1.8	11.2	4.7
10/28	27.4	7.2	1.6	10.8	
10/29	29.2	7.4	1.5	11.5	
10/30	27.6	7.3	1.6	10.7	
10/31	27.7	7.2	1.6	9.9	
平均值	27.3	7.2	1.8	13.5	5.6