

100 年 11 月南部科學工業園區高雄園區污水處理廠放流水質

日期	Temp (°C)	pH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
11/01	27.4	7.3	1.5	9.9	4.4
11/02	26.7	7.2	1.6	11.1	4.6
11/03	26.1	7.2	1.6	11.1	4.7
11/04	27.2	7.2	1.7	12.1	
11/05	26.1	7.2	2.0	12.9	
11/06	27.3	7.2	1.9	11.3	
11/07	27.6	7.2	1.9	12.1	
11/08	27.4	7.2	1.8	11.2	4.9
11/09	26.8	7.2	1.7	10.8	4.6
11/10	25.7	7.2	1.8	11.2	4.7
11/11	25.9	7.2	1.7	10.8	
11/12	26.2	7.2	1.7	11.2	
11/13	26.2	7.2	1.8	10.4	
11/14	26.3	7.2	1.7	11.6	
11/15	26.4	7.2	1.7	14.4	6.1
11/16	26.8	7.2	1.9	15.6	6.6
11/17	26.0	7.3	1.8	12.8	5.3
11/18	27.2	7.1	2.1	14.7	
11/19	26.9	7.0	2.0	14.7	
11/20	26.7	7.0	1.9	13.9	
11/21	27.1	7.1	2.0	13.5	
11/22	26.5	7.1	2.1	14.8	6.2
11/23	25.8	7.0	1.8	13.5	5.8
11/24	26.3	7.1	1.9	14.4	6.1
11/25	26.1	7.1	1.6	14.5	
11/26	24.9	7.0	2.1	14.3	
11/27	24.8	7.0	1.9	14.7	
11/28	24.3	7.0	2.0	15.9	
11/29	25.5	7.0	1.7	13.6	5.6
11/30	25.8	7.0	1.7	12.8	5.3
平均值	26.3	7.1	1.8	12.9	5.4