

101 年 01 月南部科學工業園區高雄園區污水處理廠放流水質

| 日期 | Temp (°C) | pH | SS (mg/L) | COD (mg/L) | BOD ₅ (mg/L) |
|-------|-----------|-----|-----------|------------|-------------------------|
| 01/01 | 21.7 | 7.1 | 2.0 | 14.2 | |
| 01/02 | 21.3 | 7.0 | 2.2 | 13.8 | 5.6 |
| 01/03 | 21.5 | 7.0 | 2.2 | 15.4 | 6.4 |
| 01/04 | 21.0 | 7.0 | 2.3 | 15.0 | |
| 01/05 | 20.1 | 7.1 | 2.3 | 17.0 | 7.1 |
| 01/06 | 20.2 | 7.1 | 2.0 | 15.3 | |
| 01/07 | 21.6 | 7.2 | 2.2 | 14.5 | |
| 01/08 | 21.6 | 7.3 | 2.3 | 13.7 | |
| 01/09 | 22.1 | 7.2 | 2.3 | 14.5 | |
| 01/10 | 21.2 | 7.3 | 1.8 | 14.9 | 6.1 |
| 01/11 | 21.6 | 7.2 | 2.0 | 13.3 | 6.0 |
| 01/12 | 22.2 | 7.2 | 2.4 | 14.4 | 5.6 |
| 01/13 | 21.9 | 7.2 | 2.0 | 14.8 | |
| 01/14 | 22.5 | 7.4 | 2.2 | 13.6 | |
| 01/15 | 22.7 | 7.2 | 2.0 | 15.2 | |
| 01/16 | 22.8 | 7.2 | 2.1 | 14.4 | |
| 01/17 | 21.8 | 7.2 | 2.2 | 14.1 | |
| 01/18 | 21.8 | 7.2 | 1.9 | 14.5 | 5.6 |
| 01/19 | 22.3 | 7.0 | 1.9 | 13.3 | 6.1 |
| 01/20 | 22.3 | 7.1 | 2.2 | 14.8 | 6.4 |
| 01/21 | 19.7 | 7.2 | 2.0 | 15.0 | |
| 01/22 | 18.6 | 7.2 | 1.8 | 16.6 | |
| 01/23 | 18.5 | 7.3 | 2.1 | 15.8 | |
| 01/24 | 17.9 | 7.0 | 2.4 | 15.8 | |
| 01/25 | 17.8 | 7.3 | 1.8 | 15.0 | |
| 01/26 | 20.0 | 7.1 | 1.9 | 14.0 | |
| 01/27 | 20.3 | 7.1 | 2.1 | 14.8 | |
| 01/28 | 20.1 | 7.1 | 1.8 | 14.4 | |
| 01/29 | 19.5 | 7.1 | 1.9 | 13.6 | |
| 01/30 | 20.8 | 7.1 | 2.1 | 15.6 | |
| 01/31 | 21.4 | 6.9 | 2.2 | 15.9 | |
| 平均值 | 20.9 | 7.1 | 2.1 | 14.7 | 6.1 |