

101 年 02 月南部科學工業園區高雄園區污水處理廠放流水質

日期	Temp (°C)	pH	SS (mg/L)	COD (mg/L)	BOD <sub>5</sub> (mg/L)
02/01	21.4	7.2	1.9	17.3	7.3
02/02	20.5	7.3	2.1	17.9	7.4
02/03	20.2	7.2	1.9	16.8	6.9
02/04	23.1	7.2	2.2	16.5	
02/05	23.4	7.2	1.9	17.4	
02/06	23.7	7.3	2.0	17.8	
02/07	24.1	7.3	2.0	17.9	7.3
02/08	18.5	7.3	1.6	16.5	6.8
02/09	19.5	7.2	1.7	15.7	6.4
02/10	20.6	7.2	1.6	14.8	
02/11	21.3	7.3	1.7	16.0	
02/12	21.8	7.4	2.0	16.8	
02/13	21.1	7.3	2.2	16.8	6.5
02/14	24.0	7.3	1.7	16.1	
02/15	24.1	7.2	2.0	15.1	6.7
02/16	23.0	7.2	2.3	16.2	7.1
02/17	21.6	7.2	1.8	17.9	
02/18	19.8	7.2	1.6	18.8	
02/19	20.1	7.2	1.8	17.5	
02/20	19.8	7.1	2.1	18.4	
02/21	22.3	7.0	1.7	18.3	
02/22	22.3	7.0	2.1	16.5	6.7
02/23	24.1	7.0	1.6	16.7	7.0
02/24	23.3	7.0	1.7	17.1	7.2
02/25	20.3	7.0	1.5	15.3	
02/26	20.4	7.0	2.0	16.1	
02/27	19.9	7.0	1.7	14.5	
02/28	19.6	7.0	1.6	15.7	
02/29	20.5	7.0	1.7	17.0	
平均值	21.5	7.2	1.9	16.7	16.7